



Project Compliance Inspection Report

Project	The Alexandria		
Location	Arlington, VA		
QCP Project	09.1234		
	Woodworker		Architect
<i>Firm</i>	Woodwork Today, Inc.	<i>Firm</i>	ABC Architects
<i>Contact</i>	John Smith	<i>Contact</i>	
<i>Phone</i>	(123) 123-4567	<i>Phone</i>	(123) 987-6543
<i>Fax</i>	(123) 123-4589	<i>Fax</i>	
<i>E-mail</i>	smith@woodworktodayinc.com	<i>E-mail</i>	
Inspection Date	July 6, 2009	Referenced Standard	QSI, Eighth Edition, Ver. 2
Venues Inspected	Plant; Job Site:	Quality Grade	Premium
Products Reviewed	Standing and Running Trim, Various configurations and material of casework. Flush Paneling, Stile & Rail sliding doors.		
Notes and Comments	<p>The products were built in ABC's Arlington, VA plant. Installation was by Woodwork Today, Inc. personnel in Arlington, VA.</p> <p>This project is an 86 room boutique hotel with spa and meeting room facilities. With all projects there are some nick, scratches and final adjustments required. I observed very few of these non compliant items. Overall this is a compliant Premium Grade project.</p>		
Compliance	No deficiencies noted.		
Conclusion	I find this project to be of very high quality meeting the requirements of the project documents and the referenced AWI Standards.		

Follow Up Inspection

Respectfully submitted,

Gordon Graham
 QCP Representative

NOTE: WE ARE REVIEWING FOR COMPLIANCE WITH THE REFERENCED STANDARD: QSI, EIGHTH EDITION, VER. 2 AND PROJECT SPECIFICATIONS ONLY. CONSULT THE REFERENCED STANDARD FOR ADDITIONAL REQUIREMENTS NOT MENTIONED HERE.



Item

Paneling

QS Reference

500A-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Paneling during manufacturing in Arlington plant. Note complex machining for reveal inserts.



Item

Paneling

QS Reference

1500-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Walnut paneling, stained and in finish process. Both sides receiving Catalyzed Lacquer



Item

Paneling

QS Reference

300-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Solid Walnut lock mitered panel corners.



Item

Panel concealed hanger system

QS Reference

1700-G-1

Compliance

Compliant with the Standards

Notes

Panel hangers on column ready for panel installation



Item

Paneling

QS Reference

500-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Completed installed PS Walnut paneling. Covered for construction protection.



Item

Night Stand

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Rift White Oak lock mitered leg of Night Stand. All four sides display Rift grain.



Item

Night Stand

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Four step bleached Rift White Oak night stand with solid oak dovetailed drawers.



Item

Walnut Casework

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Typical casework construction. European assembly screws. 1/2" thick applied back with correct screws and spacing.



Item

Casework

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

PS Walnut Base cabinet. Doors and drawer fronts not installed. Doors matched. Note drawer faces are horizontal grain per specification. Drawer faces butt matched.



Item

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Walnut vanity. Note shelf to left of photo. The bottom side of this shelf is finished on the bottom due to possible sight line from tub. This was done by ABC on their own, not per construction documents.



Item

Wardrobe

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Rift White oak with solid walnut inlays.



Item

Suite casework details

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Detail of solid walnut inlays



Item

Installation detail

QS Reference

1700-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Detail of walnut trim joined with non wood element. This is typical of the entire installation.



Item

Spa Casework

QS Reference

400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Spa casework, Stained rift white oak. Typical casework for spas. There are several spas with different configurations.



Item

Stile & Rail sliding door

QS Reference

1400-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

2 1/4" thick walnut stile and rail sliding door with walnut jambs and sill. This is a heavy door that slides so smooooothly with soft stops at either end of the track. Very well done.



Item

Oak paneling

QS Reference

500-G-1

Compliance

Compliant with the Standards and the Specifications

Notes

Rift white oak paneling with solid edge with reveal. Note the precise machining of the reveal to leave enough to cover the edge of the substrate.

